

CITY OF BEDFORD, OHIO

ORDINANCE NO. 023-25

AN ORDINANCE AUTHORIZING THE CITY MANAGER TO ENTER INTO A CONTRACT WITH **BUCKEYE PUMPS** FOR REPAIRS TO THE PUMPS AT THE WASTE WATER TREATMENT PLANT (WWTP) AND DECLARING AN EMERGENCY

WHEREAS, the Waste Water Treatment Plant Superintendent had obtained a quote for repairs to the existing pumps at the WWTP pursuant to NPDES permit requirements, and

WHEREAS, the Administration and Superintendent recommend **Buckeye Pumps** to perform the repair due to its familiarity with the WWTP and being the lowest quote obtained.

NOW, THEREFORE, BE IT ORDAINED by the Council of the City of Bedford, County of Cuyahoga, and the State of Ohio:

Section 1. The Council for the City of Bedford hereby authorizes the City Manager to enter into a contract with **Buckeye Pumps** for an emergency repair to the pumps in the total amount of **Nineteen Thousand Four Hundred Seventy-Nine Dollars and Zero Cents (\$19,479.00)**.

Section 2. The Council of the City of Bedford hereby authorizes the Finance Director to appropriate and pay the sum not to exceed **Nineteen Thousand Four Hundred Seventy-Nine Dollars and Zero Cents (\$19,479.00)** from **Wastewater Fund No. 501** to **Buckeye Pumps**.

Section 3. That actions of this Council concerning and relating to the passage of this legislation were adopted in an open meeting of this Council and that all deliberations of this Council and of any of its committees that resulted in such formal action were in meetings open to the public, in compliance with all legal requirements including Section 121.22 of the Ohio Revised Code.

Section 4. This ordinance is hereby declared to be an emergency measure immediately necessary for the public peace, health, safety, and welfare and for the further reason that it is immediately necessary to meet the NPDES permit requirement and to repair it in a timely manner.

WHEREFORE, this Ordinance shall take effect and be in force from and after the earliest date permitted by law.

CITY OF BEDFORD, OHIO

ORDINANCE NO. 023-25

Stanley C. Koci, Mayor-President of Council

Tracy M. Simons, CMC, Clerk of Council

Prepared and approved as to legal content by: _____
John J. Montello, Law Director

PASSED: _____

FAILED: _____

Quote Date	Expiration Date	Customer #	Order #
11/18/2024	12/18/2024	120148	32SV000351
Contact	Currency	Revision	
	USD	0	
Bill To	Ship To	Ordered From	
CITY OF BEDFORD 165 CENTER RD BEDFORD OH 44146-2738 United States	CITY OF BEDFORD 165 CENTER RD BEDFORD OH 44146-2738 United States	BUCKEYE PUMPS 1311 FREESE WORKS PL GALION OH 44833-9368 United States	
Instructions	Ship Via	Ship Point	Terms
PPY/ADD	UPSG	3200	Net 30 Days

Scope Of Supply

Thank you for the opportunity to quote your repair needs. OTC is pleased to provide the following quotation for your approval. For any questions regarding this quote please contact:

Rebekah Williams - Service Coordinator

Ryan Hoepf-Account Manager

Inspection Analysis:

Upon receipt of the customer unit, OTC disassembled, cleaned, and performed inspection. For further details regarding the inspection, see the As Found report.

Repair Delivery: 6-8 Weeks after Receipt of Order

Work Scope:

- Disassemble & Clean the Unit as Required
- Fab shaft (pump) with sleeve
- Fab enclosure tube
- Fab coupling (shaft)
- Fab bronze bushing
- Fab impeller wear ring (back)
- Fab impeller wear ring (bowl)
- Tru cut impeller wear ring
- Tru cut bowl wear ring
- Marine bowl bushing
- Sandblast impeller
- polish/check the grommet motor shaft
- Fab stuffing box bushing
- Wash N Bake stator
- Replace mechanical seal cartridge
- Epoxy coat impeller
- Assemble
- Return to Customer

Line	Item	Description	Unit
1	REPAIR - PUMP	FAIRBANKS MORSE VTSH	950140-1

Line Total: 19,479.00
 Quoted Total: 19,479.00



Quote

Freight:	0.00
Misc Charges:	0.00
Quoted Discount:	0.00
Sales Tax1:	0.00
Sales Tax2:	0.00
Quoted Net:	19,479.00

Midwest Valve Parts Supply Co., Inc.
P.O. Box 668
Chesterland, OH 44026

QUOTATION

DATE	QUOTE#
11/21/2024	024837RSS-01FPA

CUSTOMER: Mr. Rick Soltis
CITY OF BEDFORD, OH WW TREATMENT PLANT
705 WEST GLENDALE STREET
CLEVELAND, OH 44146
email: rsoltis@bedfordoh.gov

Phone #	Fax #
440-729-0008	440-729-6312
E-mail	
Sales@valvesohio.com	
Website	
www.valvesohio.com	

Inquiry No.	Terms	Delivery	Rep	FOB	Freight
		TBD	RS	DELIVERED	Prepay & Add

Qty	Item	Description	Net Ea	Total
1	REPAIR 1	LABOR, MATERIAL AND TRANSPORT, To transport FAIRBANKS MORSE to facility, and teardown and inspect for root cause analysis, and submittal of condition report and quotation for its repair	\$1760.00	\$1760.00
1	REPAIR 2	IN HOUSE PUMP REPAIR OF FAIRBANKS MORSE PUMP, S/N950140-0 MODEL VTSH INCLUDES TEARDOWN, INSPECTION, MEDIA BLAST, REPLACE THE FOLLOWING 316SS BOWL AND HEAD SHAFT STAINLESS SHAFT SLEEVE SHAFT COUPLING ALL SHAFT BRGS AND ENCL. TUBE COUPLINGS ALL BOLTING HARDWARE BRONZE IMPELLER HUB, MACHINED TO PROPER RUNNING CLEARANCE MECHANICAL SEAL (TO BE SET ONSITE) IMPELLER EYE WEAR RING AND SUCTION BOWL WEAR RING TO BE RECUT DISCHARGE BOWL HUB RING ID TO BE RECUT CAVITATION OF IMPELLER VANES WELDED ASSEMBLE AND EPOXY COAT PICKUP AND DELIVERY TO SITE INCLUDED	\$22,461.00	\$22,461.00
TOTAL				\$24,221.00

QUOTE VALID FOR 30-DAYS.