

**CITY OF CLAREMONT
NORTH CAROLINA
ORDINANCE 06-26
AN ORDINANCE TO AMEND TO THE CODE OF ORDINANCES
OF THE CITY OF CLAREMONT
TITLE 5, CHAPTER 2, ARTICLE B**

WHEREAS, the City of Claremont proposes to amend Title 5 of the City ordinances, to adopt by reference the Sewer Use Ordinance of the receiving sewer system; and

WHEREAS, the City of Claremont has entered into a contractual agreement for wastewater treatment with the City of Hickory and

WHEREAS, the contract with the City of Hickory requires that the City of Claremont adopt their Sewer Use Ordinance; and

WHEREAS, the implementation of this ordinance will enhance the City's ability to monitor and regulate potential hazards, thereby fostering a proactive approach to water safety;

NOW, THEREFORE, BE IT ORDAINED BY THE CITY COUNCIL OF THE CITY OF CLAREMONT,

Title 5, Chapter 2, Article B, Section 10 of the City of Claremont Code of Ordinances is hereby created by adding the following (new language appears as highlighted; deleted language and/or deleted sections appear as "strikethroughs"):

SEC. 5-2-10. - Sewer Use.

- (a) Through individual contracts with neighboring municipalities, Claremont provides wastewater treatment facilities to both residential and business property owners within the city's service area. Each wastewater treatment facility is operated pursuant to a municipal ordinance created in conformance with applicable laws and approved by the appropriate controlling state agency.
- (b) Every property owner whose property is connected to another municipality's wastewater treatment system, pursuant to the city's contract with said municipality, is subject to all applicable terms and conditions of said municipality's sewer use ordinance, which is adopted by the City of Claremont and incorporated in this section by reference.

Title 5, Chapter 2, Article B, Section 13 of the City of Claremont Code of Ordinances is hereby amended by adding the following (new language appears as highlighted; deleted language and/or deleted sections appear as “strikethroughs”):

Sec. 5-2-13 Local Limits.

To implement the general and specific discharge prohibitions listed in this chapter, industrial user-specific local limits will be developed ensuring that the POTW’s maximum allowable headworks loading is not exceeded for particular pollutants of concern for each industrial user. Where specific local limits are not contained for a given parameter or pollutant in an industrial user permit, the following limits will apply to all users:

~~[250]—mg/l—BOD~~
~~[250]—mg/l—TSS~~
~~[40]—mg/l—TKN~~
~~[0.003]—mg/l—arsenic~~
~~[0.003]—mg/l—cadmium~~
~~[0.061]—mg/l—copper~~
~~[0.041]—mg/l—cyanide~~
~~[0.049]—mg/l—lead~~
~~[0.0003]—mg/l—mercury~~
~~[0.021]—mg/l—nickel~~
~~[0.005]—mg/l—silver~~
~~[0.05]—mg/l—total chromium~~
~~[0.175]—mg/l—zinc~~


a.	[250]	mg/l	BOD
b.	[250]	mg/l	TSS
c.	[25]	mg/l	NH ₃
d.	[0.003]	mg/l	arsenic
e.	[0.003]	mg/l	cadmium
f.	[0.05]	mg/l	chromium (total)
g.	[0.061]	mg/l	copper
h.	[0.041]	mg/l	cyanide
i.	[0.049]	mg/l	lead
j.	[0.0003]	mg/l	mercury
k.	[0.021]	mg/l	nickel
l.	[100]	mg/l	oil & grease
m.	[0.01]	mg/l	phenol
n.	[0.005]	mg/l	silver
o.	[0.0082]	mg/l	toluene
p.	[40]	mg/l	TKN
q.	[0.175]	mg/l	zinc
r.	[6.0 – 11.0]	SU	pH
s.	[150°]	°F	Temperature

Industrial user-specific local limits for appropriate pollutants of concern shall be included in wastewater permits and are considered pretreatment standards. The City Manager may impose mass limits in addition to, or in place of, the concentration-based limits above. (Ord. of 6/6/94, No. 223-94)


Adopted this, the 7th Day of July, 2025.


Shawn R. Brown, Mayor

ATTEST:


~~Wendy L. Helm, City Clerk/HR Officer~~

APPROVED AS TO FORM:


Robert M. Grant Jr., City Attorney